

ACCURATE POWER INDUSTRIAL GENERAL TRADING LLC

STANDARD SPECIFICATIONS

1. ENGINE

Perkins four stroke heavy duty high performanceindustrial type diesel engine.

- 2. ENGINE FILTRATION SYSTEM
- Cartridge type dry air filter.
- Cartridge type fuel filter.
- Full flow lube oil filter. •
- Water filter.
- All filters have replaceable elements.

3. COOLING RADIATOR

Radiator and cooling fan, complete with safety guards, designed to cool the engine at high ambient temperatures (consult your dealer for de-12 (db) Silencer noise reduction level Maximum allowable back pressure 10 (kPa)

5. CIRCUIT BREAKER TYPE ABB 3 pole MCB. (4 pole is optional)

GENERATING SET MODEL (APP250)

Output Ratings	Prime	Standby
380-415 V, 3 ph, 50 Hz, 1500 rpm	250 KVA	275 KVA
	200 KW	220 KW

88 Perkins

Diesel Power

(contd.

Ratings at 0.8 Power Factor

0423055

0

LEROY ° SOMER

ENGINE / TECHNICAL DATA				
Engine Make	Perkins			
Engine Model		06A-		
	E70TTAG3			
Governing Type	Electronic			
Number of Cylinders	6			
Cylinder Arrangement	Vertical in line			
Bore and Stroke mm	105 x 135			
Displacement / Cubic Capacity litres	7.01			
Induction System	Series Turbocharged, air to air charge cooled			
Cycle	4 stroke			
Combustion System	Direct Injection			
Compression Ratio	15.8 <mark>:1</mark>			
Rotation	Anti-clockwise, viewed on flywheel			
Cooling System	Water - cooled			
Frequency and Engine Speed	50Hz & 1500rpm			
	Prime			
Gross Engine Power kW (hp)	226.2			
Fuel Consumption @ 50% load L/hr	28.1			
@ 75% load L/hr	41.5			
@ 100% load L/hr	56.9			
Total Coolant Capacity (inc. radiator) litres	25			
Exhaust Temperature: °C	515.8			
Radiator Cooling Air Flow (Min): m3/sec	4.42			
Combustion Air Flow: m ³ /min	13.5			
Exhaust Gas Flow: m3/min	30.9			
Fuel Tank Capacity: litres	365			

DIMENSIONS AND WEIGHT

Length cm	Width cm	Height cm	Weight* kg (wet)
263	94	188	1852

* For skid mounted genset without enclosure

+971 4 294 0033

Address: City avenue Busniess Building Opposite Pullman Residency 2 Next to Deira city Centre Port Saeed, Deira Dubai UAE

🛇 +971 56 300 0982



wet weight = with lube oil and coolant

Leroy Somer
TAL 046D
1
Н
<3.5%
6
IP23
SHUNT
2/3 (n° 6)
R150
2250 mn ⁻¹
± 1%

APP-250

POWERED

000

®Perkins

PMG Excitation System Available as Optional.

Short Circuit Capacity

CONTROL PANEL	
Make	Deep Sea
Model	DSE6110

The DSE6110 is an Auto Start Control Module for single genset applications. It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suite PC software.

Metering and Alarm indications:

- Generator frequency
- Underspeed, Overspeed
- Generator volts (L-L, L-N)
- Generator current
- · Engine oil pressure
- Engine coolant temperature
- Fuel level (Warning or shutdown) Optional
- Hours run counter
- Battery volts
- Fail to start/stop
- Emergency stop
- · Failed to reach loading voltage/frequency
- Charge fail
- Loss of magnetic pick-up signal Optional
- Low DC voltage
- CAN diagnostics and CAN fail/error

(Please refer to DSE6110 brochure for more details)

AN INSPIRED DESIGN TO MEET YOUR NEEDS

(f) www.accuratepower-group.com



ACCURATE POWER INDUSTRIAL GENERAL TRADING LLC





LEROY ° SOMER 89 Perkins Diesel Power

RATINGS DEFINATION

Prime Power

These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercially purchased power. 10% overload power is available for 1 hour in 12 hours continuous operation.

Standby Power

These ratings are applicable for supplying continuous electrical power (at variable load) in the event of a utility power failure. No overload is permitted on these ratings.

STANDARD REFERENCE CONDITIONS

Output ratings are presented at 25°C air inlet temperature, barometric pressure 100 kPa, relative humidity 30%. This generating set is designed to operate at high ambient temperatures (up to 55°C), humidity (up to 99%) and higher altitudes. De-ration may apply, please consult your dealer for specific site ratings.

Some of the specifications are not standard on all Genset models.

AVAILABLE OPTIONS & ACCESSORIES

We offer a range of optional features and accessories to tailor our generating sets to meet your power needs.

OPTIONS

- A variety of generating set control and synchronizing panels
- Additional protection alarms and shutdowns
- · Water fuel seperator
- · Water jacket heater
- Battery charger

Distributed and Serviced by:



For further information on all of the standard and optional features accompanying this product please contact your local dealer or visit www.JubailiBros.com



In line with continuous product development, we reserve theright to change specifications without notice.

Address: City avenue Busniess Building Opposite Pullman Residency Next to Deira city Centre Port Saeed, Deira Dubai UAE

+971 4 294 0033 +971 56 300 0982 +971 50 727 6909

APP-250

STANDARD SPECIFICATIONS

6. FUEL SYSTEM

On Generating Sets up to 700 KVA, the baseframe design is incorporated with an integral fuel tank with a capacity of approx. 8 hours running at Full Load. The tank is supplied complete with fill cap breather, fuel feed and return lines to the Engine and drain plug.

ALTERNATOR 7.

- 7.1 INSULATION SYSTEM
- The insulation system is Class H.

All windings are impregnated in either a triple dip thermosetting liquid, oil and acid resisting polyester varnish or vacuum pressure impregnated with a special polyester resin.

Heavy coat of antitracking varnish additional protection against moisture or condensation.

7.2 AUTOMATIC VOLTAGE REGULATOR (AVR)

The fully sealed Automatic Voltage Regulator maintains the Voltage Regulation at $\pm 1\%$. Nominal adjustment by means of a trim pot incorporated onthe AVR

7.3 MOTOR STARTING

An overload capacity equivalent to 300% of the Full Load impedance at zero Power Factor can be sustained for 10 seconds, when PMG option is fitted.

8. MOUNTING ARRANGEMENT

8.1 BASE FRAME

The complete Generating Set is mounted as a whole on a heavy duty fabricated steel Baseframe.

8.2 COUPLING

The Engine and Alternator are directly coupled by means of an SAE flange. The Engine flywheel is flexibly coupled to the Alternator rotor.

8.3 ANTI-VIBRATION MOUNTING PADS

Anti-Vibration pads are affixed between the Engine / Alternator feet and the Baseframe thus ensuring complete vibration isolation of the rotating assembly.

8.4 SAFETY GUARDS

The Fan & Fan Drive along with the Battery Charging Alternator are Safety Guard protected for personnel protection.

9. FACTORY TESTS

The Generating set is load tested before dispatch All protective devices control functions and site load conditions are simulated. The generator and it's systems are checked before dispatch.

10. EQUIPMENT FINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and durability.

11. DOCUMENTATIONS

Operation & Maintenance manual, Circuit wiring diagrams and Commissioning / Fault Finding instruction leaflets are accompanied with the Generator.

12. QUALITY STANDARDS

The equipment meets the following standards: BS4999, BS5000, BS5514 IEC 60034, VDE0530, NEMA MG 1.22 and ISO 8528.

13. WARRANTY

All of the Generating Sets are covered under a warranty policy for a period of 12 months. Warranty of the equipment is in line with manufacturers warranty terms & conditions. (check warranty statement for more details, as it may vary for different countries)

 Genuine spare parts Load banks

Auxiliary fuel tanks

ACCESSORIES

 Manual & automatic transfer switches