



### ACCURATE POWER INDUSTRIAL GENERAL TRADING LLC





# **STAMFORD**

# **GENERATING SET MODEL WVS 700**

Output Ratings	Prime	Standby
400 V,3 ph,50 Hz,1500 rpm	700 kVA	770 kVA
	560 kW	616 kW
440 V,3 ph,60 Hz,1800 rpm	727 kVA	800 kVA
	582 kW	640 kW
		A

Power Factor: 0.8

# **ENGINE / TECHNICAL DATA**

Engine Make	Volvo Penta
Engine Model	TWD1645GE
Governing Type	Electronic
Number of Cylinders	6
Cylinder Arrangement	Vertical In Line
Bore and Stroke mm	144x165
Displacement / Cubic Capacity Itrs	16.12
Aspiration	Turbocharged
Cycle	4 stroke
Combustion System	Direct Injection
Compression Ratio	16.8:1

### STANDARD SPECIFICATIONS

Volvo four stroke heavy duty high performance industrial type diesel engine

### 2. ENGINE FILTRATION SYSTEM

- Cartridge type dry air filter
- Two cartridge type fuel filters
- Full flow lube oil filter
- All filters have replacable elements

### 3 COOLING RADIATOR

Radiator and cooling fan, complete with safety guards, designed to cool the engine at high ambient temperatures(con- sult your dealer for deration factors)

### 4. EXHAUST SYSTEM

Heavy duty Industrial Exhaust Silencer

Silencer noise reduction level Maximum allowable back pressure 10.0(kP)

### 5. CIRCUIT BREAKER TYPE ABB 3 pole MCCB.(4 pole is optional)

# 6. FUEL SYSTEM

On Generating sets upto 700kVA, the baseframe design is incorporated with an integral fuel tank with a capacity of approx. 8 hours running at full load. The tank is supplied complete with fill cap breather, fuel speed and return lines to the engine and drain plug.

7. ALTERNATOR
7.1 INSULATION SYSTEM

- · Insulation : Class H
- · All windings are impregnated in either a triple dip thermosetting liquid, oil and acid resisting polyester varnish or vaccum pressure impregnated with a special
- polyester resin.
   Heavy coat of antitracking varnish additional protection against moisture or condenasation.

7.2 AUTOMATIC VOLTAGE REGULATOR (AVR) The fully sealed AVR maintains the voltage regulation at ±0.5%. Nominal adjustment by means of a trim pot incorporated on the AVR.

# 7.3 MOTOR STARTING

An overload capacity equivalent to 300% of the full load impedance at zero power factor can be sustained for 10 sec., when AREP or PMG option is fitted.

# 8. MOUNTING ARRANGEMENT

8.1 BASE FRAME

The complete generating set is mounted as a whole on a heavy duty fabricated steel baseframe.

# 8.2 COUPLING

The engine and alternator are directly coupled by means of an SAE flange. The engine flywheel is flexibly coupled to the alternator rotor.

# 8.3 ANTI-VIBRATION MOUNTING PADS

Anti-vibration pads are affixed between the engine / alternator feet and the baseframe thus ensuring complete vibration isolation of the rotating assembly.











Address: City avenue Busniess Building Opposite Pullman Residency





Frequency and Engine Speed	50Hz & 1500rpm			60Hz & 1800rpm
	Prime			Prime
Gross Engine Power kWm	595			619
Fuel Consumption @50%load I/hr	72.7			76.36
@75%load l/hr	103.75			109.04
@100%load l/hr	134.81			142.45
Oil Consumption (I/hr)	0.10			0.10
Oil Sump Capacity, I	42			42
Heat Rejection at Exhaust (Standby) kW	473	3		513
Exhaust Temperature °C Standby	50	1		497
Coolant Capacity, I	160	0		160
Combustion Air Flow (Standby) : m³/min	43.53			47.63
Exhaust Gas Flow (Standby) : m³/min	106			115
Dimension (mm) & Weight (Kg) Length	Width	Height	Weight	
Open 3900	1400	2200	4700	
Soundproof 5400	1910	2570	7100	STANDARD SPECIFICATIONS

# **ALTERNATOR DATA**

Make	Stamford	
Model	HCl634G	
No. of bearings	1	
Insulation Class	Н	
Total Harmonic Content	On load <3.5% / <2%	
Wires	6/12	
Ingress Protection	IP23	
Excitation System	Shunt / Seperately Excited	
Winding Pitch	2/3(n°6)	
AVR Model	R150 / MX321	
Overspeed	2250 mn <sup>- 1</sup>	
Voltage Regulation	±1% / ±0.5%	
Short Circuit Capacity	-	
AREP & PMG Excitation System Available as optional		

### 8.4 SAFETY GUARDS

The fan and fan drive along with the battery charging alternator are safety guard protected for personnel protection.

# 9. FACTORY TESTS

- The generating set is load tested before dispatch. All protective devices control functions and site load conditions are simulated. The generator and it's systems are checked before dispatch.
- 10. EQUIPMENT FINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and durability.

# 11. DOCUMENTATIONS

Operation and Maintenance manual, circuit wiring diagrams and commissioning/fault finding instruction leaflets are accompanied with the generator.

# CONTROL PANEL

Deep Sea

Model DSE4510
The DSE4510 is an Auto Start Control Module for single genset applications. It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suitr PC software.

Metering and Alarm Indications:

- Generator Frequency
- Underspeed, Overspeed
- Generator volts(L-L,L-N)
- Generator Current

- Engine Oil Pressure
   Engine Coolant Temperature
- Fuel Level
- Hours Run Counter
- Battery Volts Fail to start/stop
- Emergency StopFailed to reach
- loading voltage/frequency Charge fail
- Loss of magnetic pick-up signal-Optional
   Low DC Voltage
   CAN diagnostics and

- CAN fail/error